Aging SEMs: Repair, Replace, or Modernize?

Environmental Impact and Sustainable Service for SEM

Grigore Moldovan[1] and Mathias Mosig[1]

Service is a critical aspect of microscopy, as it is for all scientific equipment. It typically follows a predictable path through the lifetime of each microscope, from installation and training to regular calibration and maintenance, with occasional on-demand support for consumables or relocation. Replacing a microscope is a far more complex decision as it involves concerns about the availability of spare parts, rising downtime and labor costs, and declining software productivity, or about the increased financial burden of replacement that may result in the loss of valuable accessories and workflows. Environmental responsibility adds another layer of complexity: does a replacement increase the environmental impact, or lower it through better energy efficiency? A modern approach to service offers a clear path forward: replace only the outdated and inefficient electronics and software, while preserving the rest of the system. This modernization strategy delivers sustainable service at lower costs and with minimum environmental impact: long-term value without unnecessary waste.



Figure 1: Illustration of SEM material footprint, showing that SEM columns have the largest environmental impact and should not be replaced or scrapped because of electronics failures.

SEM Repairs: A Service Overview

Scanning Electron Microscopes (SEM) are often introduced and described with diagrams of a column with lenses, detectors, and deflectors. But for service decisions, this view is too narrow. From a service perspective, SEMs are a collection of parts, many of which do wear out and fail over time. Among these, the column itself is surprisingly resilient with minimal consumables (tips and apertures). Columns remain functional for decades when properly maintained and serviced. In contrast, the microscope electronics, power supplies, controllers, amplifiers, and control panels, fail far more often and drive most service calls.

SEM electronics can be seen as a collection of electronic boards, mounted in the plinth of the SEM or a separate rack, that power and control the microscope. They include an array of internal devices, from power supplies for the optics and detectors, to amplifiers for detectors and scanning coils, real-time controllers for the various subsystems, and hardware control panels for the operator. Fortunately, while SEM electronics are complex, they're also modular and accessible, and therefore, many failures can be resolved by replacing individual boards. Critical problems arise when these boards are no longer manufactured. But this doesn't mean the SEM itself is obsolete. Far from it.

SEM Modernization: When Repair Is Not Enough

Even if an unreplaceable board fails, the SEM's core components, like column, stage, detectors or vacuum, still function and are still able to deliver the same performance. The solution isn't to replace the entire microscope, but to exchange the complete SEM electronics, that is, to modernize it. This will not only restore full operation, but it will do so without sacrificing existing accessories and workflows. Thanks to the analog nature of SEM interfaces, modernization is straightforward; simply unplug the cables from the old electronics and plug them into the new electronics, then calibrate and adjust parameters in the new software.

Software adds another critical layer that cannot be managed by simple repairs. Aging operating systems typically run into the end of security support, which means SEM PCs are often disconnected from networks. This adds artificial limits to data transfer, remote access, and lab efficiency. However, major software updates are not feasible or sustainable on aging electronics. The modernization approach solves this, too. The refit kit includes state-of-the-art secure software alongside new electronics, bringing systems back online with



Figure 2: Illustration of SEM power consumption with and without the SEM modernization retrofit kit over a typical electronics lifetime of 8 years. Modernization adds new intelligent power management with a standby mode when idle.

Figure 3: Photo of a modernized SEM, showing that the column is kept, but electronics and software are replaced, including control panels. For space efficiency, electronics are mounted in the plinth of the SEM and are not visible here.

modern user interfaces and operating systems.

Environmental Responsibility: Keep What's Worth, Modernize What's Not

While financial cost is often the first consideration in lab administration, environmental impact is increasingly a significant aim of each lab management. SEM columns have a greater environmental impact due to the high volume of high-purity materials required and the high precision machining used for their manufacture. As with all high-performance lab equipment, electron microscopy is aiming towards ever-improving performance, often resolution, so reducing the environmental impact of column manufacture is limited in scope. While recycling the column materials for other purposes can offset this slightly, the material quality will be lost, and the environmental impact of shipping will increase. However, SEM columns are durable, and therefore, they can become environmentally efficient over time if kept in service for their entire lifetime. The actionable, environmentally responsible step is to keep the SEM column in service for as long as possible.

Electronics, by contrast to columns, have a smaller manufacturing footprint but contribute more to ongoing energy consumption. They have recently very much improved power consumption thanks to the lower power rating of newer ICs and smarter power management, including the introduction of standby mode. With these improvements, new electronics can reduce power consumption by up to 70%, which leads to a very significant reduction in environmental impact over a typical electronics lifetime of eight years, as well as reduced energy costs. The actionable, environmentally responsible step is to replace the SEM electronics.

SEM modernization, therefore, hits a sweet spot where environmental and financial perspectives align. It ensures predictable long-term service, and it creates value for all participants. For service providers, modern electronics allow for extended service contracts and ensure long-term usability. For lab management, modern electronics reduce



Figure 4: Screenshot of the modernized SEM control software, part of the retrofit kit, and compatible with the latest operating system.

Figure 5: Retrofit electronics kit enables the use of a modern user control panel for higher productivity and speed.

costs and have a minimum environmental impact. For the community, the modernization approach offers a dual benefit: environmental responsibility and sustainable service.

When to Modernize

SEM Modernization requires two conditions: the local service provider must have the training to install the modernization kit, and a modernization kit must be available for your SEM model. Service training typically takes a few days and includes learning the SEM's interfaces, third-party system connections (EDS/EBSD), and software adjustments and calibrations. This may take place remotely or onsite, depending on arrangements.

Though still new in many regions, modernization kits are available from point electronic for most Zeiss/LEO and Philips/FEI models – the most popular SEM models in Europe, where the modernization approach has been gathering momentum. Over 250 SEMs have already been modernized this way, proving the approach's growing popularity. The retrofit kits are modular and configurable for various sources (FEG/Tungsten/Lab6), stage types (manual/motorized), vacuum systems (high-vacuum/variable pressure/Environmental SEM), and detector setups (SE/BSE). They come preconfigured with settings specific to each SEM model, allowing full installation and user training to be completed in a week.

Summary

A new sustainable service approach to SEM is presented, where electronics and software are fully modernized, rather than repaired by replacement of individual boards already beyond their support period. It's shown that SEM modernization retrofit kits offer clear environmental and financial advantages over single board replacements or replacement of the entire SEM. It reduces material waste by preserving durable components (the column) and increases energy efficiency (electronics) by up to 70% lower power consumption, thus lowering both carbon footprint and operating costs. Also critical, it provides a long-term solution much beyond that of board-level replacements after end-of-support, and thus it extends the SEM's lifetime and enables stable and sustainable service arrangements. Further, it restores productivity through updated software and network access, it protects high-value SEM attachments (EDS/EBSD), and it preserves established workflows. SEM modernization, therefore, hits a sweet spot where environmental and financial perspectives align.

Affiliation

[1]point electronic GmbH, Halle, Germany

Contact

Dr. Greg Moldovan
point electronic GmbH
Halle, Germany
gm@pointelectronic.de

Online version and references:
https://bit.ly/MA-Moldovan